



SYSTEM PERFORMANCE FOR 12 MONTHS ENDING July 2015

3 Month Results:



12 Month Results:



System Performance:

YEAR	MONTH	DOWN DAYS	DAYS EXCEEDING MCL	ONLINE SMPS	BOTTLE SMPS	VALIDATION SMPS	CALIBRATION SMPS	CALIBRATION DATE	TEST SMPS	TOTAL SMPS
2015	July	2	0	171	3	27	16	2015-07-19	4	221
2015	June	0	0	175	6	18	16	2015-06-21	4	219
2015	May	0	0	177	1	27	24	2015-05-31	5	234
2015	April	0	0	172	1	18	16	2015-04-19	4	211
2015	March	0	0	179	6	18	18	2015-03-22	4	225
2015	February	0	14	131	8	18	14	2015-02-28	4	175
2015	January	0	0	153	5	18	16	2015-01-18	4	196
2014	December	0	0	179	4	18	16	2014-12-21	5	222
2014	November	2	0	160	0	19	16	2014-11-30	4	199
2014	October	0	0	179	4	27	16	2014-10-19	5	231
2014	September	0	0	173	3	18	16	2014-09-21	5	215
2014	August	0	0	181	1	18	16	2014-08-24	5	221
12MO	TOTALS	4	14	2030	42	244	200	---	53	2569

Preventive Maintenance Dates:

#	PM_Date
1	2014-05-28
2	2014-09-02
3	2014-12-04
4	2015-06-04

1 Exceedance Event(s) Detailed on Following Page(s)

EXCEEDANCE EVENT 1

